

Hydro-X System Component Selection Guide



Special Scenario

Multiple conditions control

Timer control light ON/OFF with high temperature shut down protection

Program Device Station (DSP-1)

Temp Device Station (DST-1)



When CO2 level is too high in night time, turn on exhaust fan

Program Device Station (DSP-1)

CO2 Device Station (DSC-1)



Turn off CO2 Device when turn on exhaust Fan to reduce heat

CO2 Device Station (DSC-1)

Temp Device Station (DST-1)



Turn off CO2 Device when turn on exhaust Fan to reduce humidity

Humid Device Station (DSH-1)

CO2 Device Station (DSC-1)



Multiple Divices

Multiple Humidifiers, Dehumidifiers, Heating devices, Cooling devices, 120V or 240V

Humid Device Station (DSH-1)

Temp Device Station (DST-1)

